



NOTES:

1. CONCRETE SHALL BE A COMMERCIAL MIX WITH A 28 DAY COMPRESSIVE STRENGTH OF 3300 PSI AND SHALL MEET ALL REQUIREMENTS FROM ODOT SECTION 00440.
2. SIDEWALK PANELS TO BE SQUARE (5' LONG x 5' WIDE TYP.).
4. EXPANSION JOINT MATERIAL SHALL BE PREFORMED FILLER NOT LESS THAN 1/2" WIDE AND SHALL MEET ALL REQUIREMENTS FROM ODOT SECTION 00759.
5. FOR SIDEWALKS ADJACENT TO THE CURB AND POURED AT THE SAME TIME AS THE CURB, THE JOINT BETWEEN THEM SHALL BE A TROWELED JOINT WITH A MINIMUM 1/2" RADIUS.
6. SIDEWALKS SHALL HAVE A MINIMUM THICKNESS OF 6" IF MOUNTABLE CURB IS USED, OR IF SIDEWALK IS INTENDED AS A PORTION OF A DRIVEWAY. OTHERWISE SIDEWALK SHALL HAVE A MINIMUM THICKNESS OF 4".
7. CONCRETE SHALL HAVE A BROOM FINISH, ALL JOINTS SHALL BE EDGED.
8. WIDTH OF PLANTER STRIP IS MEASURED FROM FACE OF CURB. WIDTH OF A CURB-TIGHT SIDEWALK IS MEASURED FROM BACK OF CURB.



**CITY OF HAPPY VALLEY  
ENGINEERING DIVISION**  
16000 SE MISTY DRIVE  
HAPPY VALLEY, OR 97086

**DWG NO: 250**

CITY ENGINEER  
CAROL EARLE, P.E.

**SIDEWALK**

DATE: 4/1/2019

REVISED BY: PCB/JHH